

DETECTED SAMPLE RESULTS:
Chemical Contaminants

Contaminants	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Nitrate	10	10	6.04	5.0-6.04	PPM	2020	N	Runoff from fertilizer use leaching from septic tanks, erosion of natural deposits.
Distribution Chlorine	MRDL=4	MRDLG=4	0.43	0.43-0.93	PPM	2020	N	Water additive to control microbes.
TTHM	80	NA	39.7	8.8-39.7	PPM	2020	N	By-product of drinking water chlorination.
HAA5	60	NA	28.5	5.9-28.5	PPM	2020	N	By-product of drinking water chlorination.
Radium 228	5	0	1.1	NA	PPM	2015	N	Erosion of natural deposits.

Entry Point Disinfectant Residual

Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y / N	Sources of Contamination
Chlorine	0.4	0.4	0.40-2.1	PPM	1/28/2020	N	Water additive used to control microbes.

Lead and Copper

Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Units	# of sites above AL of Total Sites	Violation Y\N	Sources of Contamination
Lead (2019)	15	0	0.006	PPB	0 out of 20	N	Corrosion of household plumbing
Copper (2019)	1.3	1.3	0.16	PPM	0 out of 20	N	Corrosion of household plumbing

Microbial

Contaminants	MCL	MCLG	Highest # or % of Positive Samples	Violation Y/N	Sources of Contamination
Total Coliform Bacteria	For systems that collect < 40 samples/month More than 1 positive monthly sample For systems that collect ≥ 40 samples/month 5% of monthly samples are positive	0	0	N	Naturally present in the environment
Fecal Coliform Bacteria or E. Coli	0	0	0	N	Human & animal fecal waste